

- 1. **Fuel in tanks shall not exceed one-eighth (1/8th) of a tank.
- 2. **Vehicles shall not be fueled or defueled within the building.
- 3. Positive cable on the battery disconnected.
- 4. **Fuel Tanks and fill openings shall be closed and sealed to prevent tampering. If fuel tank is locking with a key, OKAY. If not, fuel tank cover must be taped over.
- 5. Once parked inside on the show floor: unhook battery, tape off gas cap, and leave hood up for inspection. Keys must remain in the hall with Show Management. Turn in Keys to Show Management or Security before leaving.
- 6. WHEEL CHOCKS At a minimum, place one at front left tire and one at right rear tire so it will not roll. A triangle or piece of wood will work.
- 7. An ABC, 5lb, "to date" Fire Extinguisher is required for each booth or area that has a vehicle. (Must be stamped or tagged the current year 2024, or original receipt showing purchased in the last year if the date is 2022 or 2023)
- 8. Supply a drip pan for underneath the vehicle.
- 9. Electric Vehicles: Kill Switch if applicable must be turned off and taped over. Number 1, 2, & 4 above not applicable to electric vehicles.