IMPORTANT FIRE MARSHAL RULES / REGULATIONS

PLEASE READ CAREFULLY!

Following is for Exhibitors with Fire Places / Propane Burners:

A permit needs to be filed with Dulles Expo Center / Fairfax County Fire Marshal's office

- 1. All materials in close proximity to Fireplace / Propane Burners must be flame resistant. You must have in your possession and be prepared to show documentation that the material is flame retardant.
- 2. Propane fuel for the fireplace is limited to one container per exhibitor, the capacity of the propane container is limited to a maximum of <u>1 (one) pound of LPG gas</u>
- 3. Extra propane tanks CANNOT be stored in the building, new propane tanks can be brought in on as needed basis only with prior approval from the Dulles Expo Center.
- 4. Exhibitors must be in the booth at all times when Fireplace is turned on. If the exhibitor leaves their booth at any time, the fireplace must be fully turned off.
- 5. Exhibitor must have quick and easy accessibility to a 5lb Fire Extinguisher of type ABC in their booth.
- 6. No items or displays can be above the fireplace at any time.
- 7. These conditions must be adhered to and are subject to FINAL APPROVAL OF THE FIRE MARSHAL AT TIME OF INSPECTION.
- 8. Lit Candles are Not Allowed at Dulles Expo Center, No Exceptions.

** Where required to be flame resistant, decorative materials shall be tested by an approved agency and meet the flame propagation performance criteria of NFPA 701. Reports of test results shall be prepared in accordance with NFPA 701 and furnished to the fire code official upon request.